

RESOLUTION NO. 96-157

A RESOLUTION OF THE LODI CITY COUNCIL
REJECTING NON-RESPONSIVE BIDS AND AWARDING CONTRACT
FOR WHITE SLOUGH WATER POLLUTION CONTROL FACILITY EMERGENCY
AUTOMATIC TRANSFER SWITCH REPLACEMENT

=====

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened on September 25, 1996 at 11:00 a.m. for White Slough Water Pollution Control Facility Emergency Automatic Transfer Switch Replacement, described in the specifications therefor approved by the City Council in July 3, 1996; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as follows:

<u>Bidder</u>		<u>Bid Amount</u>
Engineer's Estimate		\$ 142,267
Central Sierra Electric*	Jackson	\$ 78,900
Collins Electric*	Stockton	\$ 108,999
B&H Electric*	Lodi	\$ 112,000
Con J. Franke Electric	Stockton	\$ 142,424
Sam's Electric	North Highlands	\$ 150,977

* Non-responsive bids - equipment not as specified.

WHEREAS, bids were to be received on July 24, 1996 and no bids were submitted; and

WHEREAS, the City's consultant, Geib Engineering, contacted various contractors to find out why bids were not submitted for this project; and

WHEREAS, Geib Engineering then revised the specifications to allow more options for providing a secondary power source for the treatment plant during construction, and the project was then rebid; and

WHEREAS, bids were opened on September 25, 1996 and five bids were received; and

WHEREAS, Geib Engineering then reviewed the transfer switches each of the bidders planned to use for this project and found that bids from Central Sierra Electric, Collins Electric and B&H Electric bids were based on a proposal from Zenith which took exception to several items in the City's transfer switch specifications; and

WHEREAS, the Zenith transfer switch would not allow the City to work on the switch without shutting down the entire treatment plant; and

WHEREAS, it is the recommendation of Geib Engineering that the bids from Central Sierra Electric, Collins Electric and B&H Electric be rejected as being nonresponsive bids, and that the project be awarded to Con J. Franke Electric in the amount of \$142,424.00.

NOW, THEREFORE, BE IT RESOLVED by the Lodi City Council that the non-responsive bids from Central Sierra Electric, Collins Electric and B&H Electric are hereby rejected and the award of the contract for White Slough Water Pollution Control Facility Emergency Automatic Transfer Switch Replacement, be and the same is hereby awarded to Con J. Franke Electric in the amount of \$142,424.00; and

BE IT FURTHER RESOLVED that \$160,000.00 be appropriated from the Sewer Reserve Fund to cover this project.

Dated: November 6, 1996


I hereby certify that Resolution No. 96-157 was passed and adopted by the City Council of the City of Lodi in a regular meeting held November 6, 1996 by the following vote:

AYES: Council Members - Davenport, Mann, Pennino, Sieglock
and Warner (Mayor)

NOES: Council Members - None

ABSENT: Council Members - None

ABSTAIN: Council Members - None


for JENNIFER M. PERRIN
City Clerk